
JUSTIFICATION STATEMENT FOR CONTRACT AWARD

Weber State University
Emergency Generator for the Technology Education Building
DFCM Project No. 02280810

The selection committee authorizes DFCM to contract with Kitmund Electric for the emergency generator project at Weber State University. Their favorable cost submittal and early project completion date were the considerations for this project award.

Final Ranking

1. E
2. C
3. H
4. T

VBS Selection Final Scoring Matrix

Weber State University - Emergency Generator for the Technology Education Building

DFCM Project No. 02280810

12 February 2003

Selection Criteria	T			E			C			H		
Past Performance Rating	5	4	4	5	4	4	5	4	5	5	5	5
Strength of Team	4	4	5	5	5	5	5	5	5	5	5	5
Schedule	4	4	5	5	5	4	5	5	4.5	5	4	5
Project Management Approach	5	5	5	5	5	4	4	5	5	4	5	5
Scheduling of Power Outages for Removal and Installation of Equipment	5	4	5	5	4	5	5	5	5	5	5	5
Coordination of Ventilation and Exhaust for the New Generator	4	5	5	5	5	5	4	5	4.5	5	5	5
Coordination of Removal of Existing Generator with New Equipment Availability	5	4	4	5	5	4	5	4	5	5	5	5
The Degree to Which Control Wiring for Transfer Switches and All Auxiliary Equipment Functions Properly when Placed in Service	5	5	5	5	4	4	4	4	5	5	5	5

**DEPARTMENT OF ADMINISTRATIVE SERVICES
DIVISION OF FACILITIES CONSTRUCTION AND MANAGEMENT**

PROPOSALS COVERING:

DATE: February 6, 2003

EMERGENCY GENERATOR AT TECH ED BLDG
WEBER STATE UNIVERSITY
OGDEN, UTAH

DFCM Project No: 02280810
Construction Budget: \$180,000

CONTRACTOR	BID SEC	ADD REC	BASE BID	ALTERNATE (Bypass Isolation in 1600 AMP transfer switch)	ALTERNATE (150 AMP ATS without bypass isolation)	ALTERNATE (150 AMP ATS with bypass isolation)	SUBLIST RECD	COMPL TIME
T	BB	1,2	\$178,600	\$32,163	\$2,974	\$7,980	Yes	120 days
E	BB	1,2	183,000	(21,000)	(4,000)	11,000	Yes	5/31/03
C	BB	1,2	165,000	23,251 *	4,228	4,264 *	Yes	120 days
H	BB	1,2	179,422	33,092	9,494	2,381	Yes	135 days

* **NOTE:** Taylor Electric included the following statement on his bid - "If one or both of alternates #1 and #3 are accepted an additional adder of \$1,754 must be added to cover costs of changing generator supplier."

I hereby certify this to be a true and exact
tabulation of proposals received for the above named
project on February 6, 2003 at 3:30 p.m.

Susan L. Smith
Contract Coordinator